ZP755B-2P

Ziton series Addressable Base Sounder (Polar White)

General

The ZP755B-2P POLAR WHITE base sounder combines a detector base and audible sounder in a single stylish moulding. The unit provides an elegant solution for areas where the installation of a separate detector and sounder would prove expensive, both in equipment capital value and system wiring costs. Installation time is further reduced as the moulding plugs directly onto a first fix base eliminating the need for any internal connections.

The ZP755B-2P is perfectly suited for any location involving multiple alarm sounders, for example hotel bedrooms and risk areas comprising many small compartments.

Independent addressing for the detector and alarm facility is featured, with sound levels conforming to EN54 Part 3.

Advanced acoustic design

High efficiency acoustic design and a low energy sound gun transducer enable up to 60 sensors with sounder bases to be connected to a 1 km loop of 1.5mm² cable, with a wiring run of 50 metres to the first device. In systems where loop lengths or current requirements are excessive, the sounder base can be powered directly from an external power supply.

Microphone output test

The ZP755 range features a unique self test facility that is automatically activated during routine sounder testing. A built in microphone circuit measures sound output level and automatically signals the sounder address to the control panel, should the output test fail.

Continuous, intermittent and two-tone audible outputs are available from which any combination can be chosen to provide alert and evacuate, two stage alarms. Sound types comply with most international codes (e.g. BS 5839 Part 1 recommended frequencies).



Details

- Detector and sounder from a single wiring point – minimising installation costs
- Powered directly from the ZP loop
- Up to 60 detectors with sounders directly on the loop
- Separate addresses selectable for detector and sounder
- High efficiency sound gun transducer
- Compatible with all ZP loop devices
- Wide range of international sound types and frequencies
- EN54:3 approved and CPR certified

ZP755B-2P

Ziton series Addressable Base Sounder (Polar White)

Technical specifications

General

Compatibility	All ZP7 addressable systems
Addressing method	Dip-Schalter
Monitoring	Device removal, Device type, Open circuit, Short circuit, Sound output

Electrical

Operating voltage	Loop 19.5 to 20.5 V External 18 to 30 VDC

Sounder

Output level	<79 dB(A) (tone dependant)
Selectable tones	user configurable

Physical

Physical dimensions	127 x 47 mm (Ø x H)
Net weight	150 g
Colour	Polarweiß
Mounting type	Oberflächenmontage
Material	Geformter Thermoplast

Environmental

Operating temperature	-10 to +60°C
Storage temperature	-20 to +70°C
Relative humidity	1 to 95% (noncondensing)
Environment	Drinnen
IP rating	IP21C

Regulatory

Certification	EN54-3
Standards	CPR Certified

Mounting

	Surface mount with plug in base - SPB-2P (White)

Loop current

Quiescent (when loop powered)	820µA
Active (when loop powered)	4.5mA
Quiescent (when externally powered)	470µA
Active (when externally powered)	500µA

Devices per loop (max)

	60 (1km loop of 1.5mm² cable, 50 m to first device)

Wiring


	2 core loop

Addressing method

	7 way dipswitch

Compatible products

Category	Reference	Description
Detection device	ZP720-3P	Ziton series addressable heat detector
Detection device	ZP730-2P	Ziton series addressable optical detector
Detection device	ZP732-2P	Ziton series Addressable Dual Detector (Optical & Heat), Polar White
Detection device	ZX832-3P	Ziton series addressable multisensor (optical / heat)
Notification device	70802	Red Cap for ZP755B Series Notification Devices
Notification device	SPB-2P	Plug-in base, polar white
Notification device	ZP755-COV-P	Ziton series Detector Base Cover (Polar White)



KIDDE COMMERCIAL

As a company of innovation, Kidde Global Solutions reserves the right to change product specifications without notice. For the latest product specifications, visit firesecurityproducts.com online or contact your sales representative.

Last updated on 16 October 2026 - 11:28